



CERTIFICATE

No. 00062/101/1/2024
on November 13th, 2024

Certification body of EVPÚ a.s. confirms the compliance of the products
with requirements of undermentioned standards.

Product: **Plastics Electric Meter Box** 

Type: **PRE-N Z 630A 116 2K**

Specification: **230/400V, 630A, 50Hz, IP44 / IP20 from the front, after opening the door**

Other variants: **See Annex 1**

Client: **SEZ Krompachy a.s.**
Hornádska 1, 053 42 Krompachy, Slovak Republic

Identification Code: **36177644**


Manufacturer: **SEZ Krompachy a.s.**
Hornádska 1, 053 42 Krompachy, Slovak Republic

Standards: **EN IEC 61439-1: 2021**
EN IEC 61439-5: 2023

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0197/24/C**
of **November 13th, 2024**.

Used standards are harmonized with directive of the European parliament and of the Council 2014/35/EU
transposed into Slovak government decree No. 148/2016 Z. z.

Validity of certificate is limited for the period
from: **November 13th, 2024**
until: **November 12th, 2027**



Michal Mišík


Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate
invalid. The product liability rests with the manufacturer or his representative.

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk

Annex 1 to Certificate No. 00062/101/1/2024

Other variants: **RE-D, RE-D2, RE-J, RE-J1, RE-J2, RE-J4, REN, RVO**

Ratings of other variants: **3NPE (PEN) 400V ~, 50Hz, 400V/230V, 63A, 10kA, IP44**



A handwritten signature in blue ink, consisting of a series of loops and strokes, positioned to the right of the red stamp.