



CERTIFICATE

No. 00003/101/1/2025

on January 31st, 2025

Certification body of EVPÚ a.s. confirms the compliance of the products
with requirements of undermentioned standards.

Product: **Plastics Electric Meter Box** 

Type: RE-

Derived variants: RE-D, RE-D2, RE-J, RE-J1, RE-J2, RE-J4, REN, RVO

Specification: 3NPE (PEN) 400V~, 50Hz, 400V/230V, 63A, 10kA, IP44

Client: **SEZ Krompachy a.s.**
Hornádska 1, 053 42 Krompachy, Slovak Republic


Identification Code: **36177644**

Manufacturer: **SEZ Krompachy a.s.**
Hornádska 1, 053 42 Krompachy, Slovak Republic

Standards: **EN IEC 61439-1: 2021**
EN IEC 61439-5: 2023

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0018/25/C** of
January 31st, 2025.

Validity of certificate is limited for the period
from: **January 31st, 2025**
until: **January 30th, 2028**



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate
invalid. The product liability rests with the manufacturer or his representative.

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk