



CERTIFICATE No. 00058/101/1/2023
on October 2nd, 2023

Certification body of EVPÚ a.s. confirms the compliance of the products
with requirements of undermentioned standards.

Product: **Modular switch**

Type: **RV 120 125A**

Derived variants: **RV 121, RV 121+N, RV 122, RV 123, RV 123+N, RV 124**

Specification: **Ith = 125A, 230Vac, 400Vac, AC 22A/Ie = 100A,
AC23/Ie = 40A, Ui = 690V, Uimp = 6kV, IP20**

Client: **SEZ Kropachy a.s.,
Hornádska 1, 053 42 Kropachy, Slovak Republic**

Identification Code: **36177644**


Manufacturer: **SEZ Kropachy a.s.,
Hornádska 1, 053 42 Kropachy, Slovak Republic**

Standards: **EN 60947-1: 2007 + A1: 2011 + A2: 2014
EN 60947-3: 2009 + A1: 2012 + A2: 2015**

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0223/23/C** of
October 2nd, 2023.

Used standards are harmonized with directive of the European parliament and of the Council 2014/35/EU
transposed into Slovak government decree No. 148/2016 Z. z.

Validity of certificate is limited for the period
from: **October 2nd, 2023**
until: **October 1st, 2026**



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate
invalid. The product liability rests with the manufacturer or his representative.

041251

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk