



CERTIFICATE No. 00004/101/1/2023
on January 12th, 2023

Certification body of EVPÚ a.s. confirms the compliance of the products with requirements of undermentioned standard.

Product: **Residual current operated circuit – breakers without integral overcurrent protection**
SEZ

Type: **PFB2**

Derived variants: **See Annex 1**

Specification: **$U_n = 230V$; $I_n = 16; 25; 40; 63 A$; $I_{nc} = 10 kA$; $I_{\Delta n} = 0,01; 0,03; 0,1; 0,3; 0,5 A$; 50 Hz, IP20 / IP40; type A**

Client: **SEZ Kropachy a.s.,
Hornádska 1, 053 42 Kropachy, Slovak Republic**

Identification Code: **36177644**


Manufacturer: **SEZ Kropachy a.s.,
Hornádska 1, 053 42 Kropachy, Slovak Republic**

Standard: **EN 61008-1: 2012 + A2: 2014 + A1: 2014 + A11: 2015 + A12: 2017**

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0004/23/C** of January 12th, 2023.

Used standard is harmonized with directive of the European parliament and of the Council 2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z.

Validity of certificate
is limited for the period
from: **January 12th, 2023**
until: **January 11th, 2026**



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

054517

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk

Annex 1 to Certificate No. 00004/101/1/2023

Derived variants:

Type – nominal current (A)	Number of poles	Nominal voltage (V)	Nominal difference current (A)
PFB2 - 16	2	230	0,01; 0,03; 0,1; 0,3; 0,5
PFB2 - 25	2	230	0,01; 0,03; 0,1; 0,3; 0,5
PFB2 - 40	2	230	0,03; 0,1; 0,3; 0,5
PFB2 - 63	2	230	0,03; 0,1; 0,3; 0,5

