



# CERTIFICATE

No. 00036/101/1/2024

on July 1<sup>st</sup>, 2024

Certification body of EVPU a.s. confirms the compliance of the products with requirements of undermentioned standard

Product: **Residual current operated circuit-breakers without integral overcurrent protection**



Type: **Typ: PFB4**

Derived variants: **See Annex 1**

Specification:  **$U_n = 400V$ ,  $I_n = 16, 25, 40, 63 A$ ,  $I_{nc} = 10 kA$ ,  
 $I_{\Delta n} = 0.03, 0.1, 0.3, 0.5 A$ , 50 Hz, IP20 / IP40**

Client: **SEZ Krompachy a.s.**  
**Hornádska 1, 053 42 Krompachy, Slovak Republic**

Identification Code: **36177644**


Manufacturer: **SEZ Krompachy a.s.**  
**Hornádska 1, 053 42 Krompachy, Slovak Republic**

Standard: **EN 61008-1: 2012 + A1: 2014 + A2: 2014 + A11: 2015 + A12: 2017**

Results of tests of mentioned products are summarized in Final report on assessment  
No. 0-0120/24/C of July 1<sup>st</sup>, 2024.

Used standard is harmonized with directives of the European parliament and of the Council 2014/35/EU  
transposed into Slovak government decree No. 148/2016 Z. z.  
and 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate is limited for the period  
from: **July 1<sup>st</sup>, 2024**  
until: **June 30<sup>th</sup>, 2027**



Michal Mišiak


Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPU a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, [www.evpu.sk](http://www.evpu.sk)



Derived variants:

Type – nominal current (A)	Number of poles	Nominal voltage (V)	Nominal difference current (A)
PFB4 – 16	4	400	0,03; 0,1; 0,3; 0,5
PFB4 – 25	4	400	0,03; 0,1; 0,3; 0,5
PFB4 – 40	4	400	0,03; 0,1; 0,3; 0,5
PFB4 – 63	4	400	0,03; 0,1; 0,3; 0,5



A handwritten signature in blue ink, consisting of a stylized, cursive script.