



# CERTIFICATE

No. 00037/101/1/2024

on July 2<sup>nd</sup>, 2024

Certification body of EVPU a.s. confirms the compliance of the products with requirements of undermentioned standard.

Product: Residual current circuit-breakers with overcurrent protection



Type: PFI2...

Derived variants: See Annex 1

Specification:  $U_n = 230 \text{ V}$ , 50 Hz,  $I_n = 6, 10, 13, 16, 20, 25, 32, 40\text{A}$ ; Char. B a C,  
 $I_{\Delta n} = 10; 30; 100; 300 \text{ a } 500 \text{ mA}$  (6 to 25A);  
 $I_{\Delta n} = 30; 100; 300 \text{ a } 500 \text{ mA}$  (6 to 40A)  $I_{cn} = 10\text{kA}$ ; IP20/IP40; type A

Client: SEZ Krompachy a.s.  
Hornádska 1, 053 42 Krompachy, Slovak Republic

Identification Code: 36177644


Manufacturer: SEZ Krompachy a.s.  
Hornádska 1, 053 42 Krompachy, Slovak Republic

Standard: EN 61009-1: 2012 + A1: 2014 + A2: 2014 + A11: 2015  
+ A12: 2016 + A13: 2021

Results of tests of mentioned products are summarized in Final report on assessment  
No. 0-0121/24/C of July 2<sup>nd</sup>, 2024.

Used standard is harmonized with directives of the European parliament and of the Council  
2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z.  
and 2014/30/EU transposed into Slovak government decree No. 127/2016 Z. z.

Validity of certificate is limited for the period  
from: July 2<sup>nd</sup>, 2024  
until: July 1<sup>st</sup>, 2027



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPU a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, [www.evpu.sk](http://www.evpu.sk)

Page 1 / 2 F COCV 7.7.9 Rev.2

056309



Annex 1 to Certificate No. 00037/101/1/2024

Derived variants:

