



CERTIFICATE

No. 00060/101/1/2025

on October 29th, 2025

Certification body of EVPU a.s. confirms the compliance of the products
with requirements of undermentioned standard

Product: Circuit breaker **SEZ**[®]

Type: PR 120

Derived variants: PR 121, PR 121N, PR 122, PR 123, PR 123N, PR 124

Specification: In = from 40 to 125A;
Un = 230Vac; 230/400Vac and 400Vac; 50Hz;
Icn = 10kA;
Ics = 7,5kA;
char. B, C, D; IP20

Client: SEZ Krompachy a.s.
Hornádska 1, 053 42 Krompachy, Slovak Republic

Identification Code: 36177644


Manufacturer: SEZ Krompachy a.s.
Hornádska 1, 053 42 Krompachy, Slovak Republic

Standard: EN 60898-1: 2019 + A1: 2024 + A11: 2024

Results of tests of mentioned products are summarized in Final report on assessment
No. 0-0241/25/C of October 29th, 2025.

Used standard is harmonized with directive of the European parliament and of the Council 2014/35/EU
transposed into Slovak government decree No. 148/2016 Z. z.

Validity of certificate is limited for the period
from: October 29th, 2025
until: October 28th, 2028



Michal Miš i a k

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate
invalid. The product liability rests with the manufacturer or his representative.

EVPU a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk

Page 1 / 1 F COCV 7.7.9 Rev.2

056458