



CERTIFICATE

No. 00012/101/1/2026

on January 27th, 2026

Certification body of EVPU a.s. confirms the compliance of the products with requirements of undermentioned standard.

Product: Residual current operated circuit – breakers without integral overcurrent protection



Type: PFB2

Derived variants: See Annex 1

Specification: $U_n = 230V$; $I_n = 16; 25; 40; 63 A$; $I_{nc} = 10 kA$;
 $I_{\Delta n} = 0,01; 0,03; 0,1; 0,3; 0,5 A$; 50 Hz, IP20 / IP40; type A

Client: SEZ Kropachy a.s.,
Hornádska 1, 053 42 Kropachy, Slovak Republic

Identification Code: 36177644


Manufacturer: SEZ Kropachy a.s.,
Hornádska 1, 053 42 Kropachy, Slovak Republic

Standard: EN 61008-1: 2012 + A2: 2014 + A1: 2014 + A11: 2015 + A12: 2017

Results of tests of mentioned products are summarized in Final report on assessment No. 0-0020/26/C of January 27th, 2026.

Used standard is harmonized with directive of the European parliament and of the Council 2014/35/EU transposed into Slovak government decree No. 148/2016 Z. z..

Validity of certificate is limited for the period
from: January 27th, 2026
until: January 26th, 2029



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPU a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, www.evpu.sk

055742

Annex 1 to Certificate No. 00012/101/1/2026

Derived variants:

Type – nominal current (A)	Number of poles	Nominal voltage (V)	Nominal difference current (A)
PFB2 - 16	2	230	0,01; 0,03; 0,1; 0,3; 0,5
PFB2 - 25	2	230	0,01; 0,03; 0,1; 0,3; 0,5
PFB2 - 40	2	230	0,03; 0,1; 0,3; 0,5
PFB2 - 63	2	230	0,03; 0,1; 0,3; 0,5

